

Bostik Bostik FP340 Pipe Wrap

VASTLY EXPANDING WRAP IN CASE OF FIRE



Product Description

Bostik FP340 Pipe Wrap is a flexible sleeve which expands vastly in case of fire. Each pipe wrap consists of a graphite based reactive intumescent strip, which reacts to heat and closes the opening left by the softening plastic pipe or combustible pipe insulation in a fire. The pipe wrap is installed completely around the pipes or insulation and secured with the self-adhesive tape. The annular space around the pipe wrap is sealed with Bostik FP320 Fire Batt and Bostik FP310 Intumescent Acoustic Acrylic. LIMITATIONS - Only limited test data are available for using Bostik FP340 Pipe Wraps in FP 320 Fire Batts in concrete floors. - Before application consult the installation instructions and ETA to ensure to achieve the intended fire resistance Available on request: - Material safety data sheet - Installation instructions FP340 Pipe Wrap - ETA 19/0390

Benefits

- CE-marked
- Fire classifications up to 240 minutes
- Classified for fire sealing in all types of constructions
- Very good sound insulation
- Very easy to install
- Certified to the latest European standards EN 1366-3
- CE marked to ETAG 026-2
- Fire resistance up to 4 hours for both integrity and insulation
- For plastic pipes and metal pipes with continuous combustible pipe insulation
- For plastic pipes with cables (conduits)
- Certified for PVC-U, PVC-C, PE (LD-PE,MD-PE-HD-PE), ABS, SAN+PVC and PP pipes

- Tested and certified for U/U pipe end applications
- Classified for fire sealing in all types of constructions
- No emissions, environmental and user friendly
- Very easy to install
- Very good sound insulation
- Unlimited storage time (under correct conditions)

Applications

Bostik FP340 Pipe Wrap is designed to maintain the fire resistance of fire separating walls and floors when these are breached by continuous plastic pipes or metal pipes with combustible insulation, and may be used in gypsum, masonry or concrete walls and concrete floors. Bostik FP340 Pipe Wrap prevents the spread of heat, smoke and fire to the next compartment.

Directions Of Use

Fix a suitable pipe wrap around the service penetration and fasten with the tape as tight as possible in order to prevent any excess opening between the pipe wrap and the service. In floors, only one pipe wrap is required to be installed flush with the soffit so that the edge of the wrap is visible from the underside when back-filled. For walls it is essential to fit a wrap on both sides of the wall, again with the edge just visible. Where wraps are installed in hollow core slabs or planks, the tubular voids should be filled with stone-wool insulation, normally the same thickness as the depth of the floor. Bostik FP340 Pipe Wrap may be installed in a Bostik FP320 Fire Batt. Cut the hole around the penetrating service to be sealed slightly oversize so that the pipe wrap may be slid in to the middle of the board. Finally the end of the pipe wrap is sealed with Bostik FP310 Intumescent Acoustic Acrylic on both outer sides. Before application consult the installation instructions and ETA to ensure to achieve the intended fire resistance.

Additional information

Base		Graphite inlay in plastic sleeve
Fire behaviour		1366-3

These are typical values

Limitations

Bostik Benelux B.V

Denariusstraat 11, 4903 RC Oosterhout, The Netherlands
Phone: +31 (0)162491000, E-mail: info@bostik.com
www.bostik.com | www.denbraven.com

17-05-2024
05:31:24
CEST



Bostik Bostik FP340 Pipe Wrap

VASTLY EXPANDING WRAP IN CASE OF FIRE

Surface Preparations and Finishing

Paintability

Not paintable.

Cleaning

Colour(s)

- White

Packaging

- Sleeve
- Roll

For product specifications, please refer to the Product Detail Page

Shelf Life

Certifications

	EN 1366-3
--	-----------

Health & Safety

Product Safety Data Sheet must be read and understood before use.
These are available on request and via our websites

Warranty & Guarantee

Bostik warrants that its product complies, within its shelf life, to its specification.

Disclaimer

All information in this document and in all our other publications (including electronic ones) is based on our current knowledge and experience and is the exclusive (intellectual) property of Bostik. No part of this document may be copied, shown to third parties, reproduced, communicated to the public or used in any other way without Bostik written consent. The technical information in this document serves as an indication and is non-exhaustive. Bostik is not liable for any damage, either directly or indirectly, due to (editorial) errors, incompleteness and/or incorrectness of this document. This includes, but is not limited to, incompleteness and/or incorrectness due to technological changes or any research conducted between the date of publication of this document and the date on which the product is acquired. Bostik reserves the right to amend the wording of this document. Bostik cannot be held liable for any damage, either directly or indirectly, due to the use of the product(s) depicted in this document. The user must read and understand the information in this document and other documents relating to the products prior to the use of the product. The user is responsible for performing all the requisite tests to make sure that the product is suitable for its intended use. We have no influence in what way the product is applied and/or any circumstances relating to events occurring during storage or transport and therefore we do not accept any liability for damage whatsoever. All deliveries are made exclusively in accordance with our general terms of conditions which have been filed at the Dutch Chamber of Commerce.

Bostik Benelux B.V

Denariusstraat 11, 4903 RC Oosterhout, The Netherlands
Phone: +31 (0)162491000, E-mail: info@bostik.com
www.bostik.com | www.denbraven.com

17-05-2024
05:31:24
CEST